

### Clarification on the Bidder's Queries Received

SN	RFP Volume	RFP Section and Point No.	Query / Content of RFP/Corrigendum Requiring Clarification(s)	Query/Change/Clarification Required	Clarification
1	RFP Vol 1 of 3 - Scope of Services	Section 5.8	RFP Page No. 51, Corrigendum Page 4  5.8 - Application Hosting on Cloud Services	<p>We would like to draw your kind attention to the MeitY guidelines saying that DC &amp; DR should be 100km apart and do not mandate being in separate seismic zones.</p> <p>Therefore, we seek your guidance on whether the MeitY guidelines would take precedence over the clause mentioned in the latest corrigendum?</p>	<p>DC and DR sites should be in different seismic zones (Pre 2001 seismic zones classifications also permitted as per Government of India Standards) with at least a distance of 100 KMs.</p> <p>For any query related this clause, MeitY Best Practices outlined would take precedence over the clause. Please refer to the link:  <a href="https://www.meity.gov.in/writereaddata/files/DR%20Best%20Practices.pdf">https://www.meity.gov.in/writereaddata/files/DR%20Best%20Practices.pdf</a> for the best practices outlined by MeitY.</p>